

Test Report

Document No.	B9016944	Copy No.	1	Number of pages	33
Apparatus	Three-phase dry-type cast-resin power transformer, for continuous duty, with external cooling by air natural convection AN/AF 5,5 MVA - 34,5 kV / 0,69 kV				
Designation	DRY				
Serial Number	KT-19-5663				
Manufacturer	ELTAŞ TRANSFORMATÖR SAN. VE TİC. A.Ş.				
Client	ELTAŞ TRANSFORMATÖR SAN. VE TİC. A.Ş. Atatürk Organize Sanayi Bölgesi 10046 Sokak No.4 35620 Çiğli İzmir Turkey				
Tested for	-				
Date(s) of tests	September 6 to 7, 2019				
Tested by	CESI S.p.A. Via Rubattino, 54 20134 – Milano, Italy				
Test performed	Verification of the dynamic ability to withstand short-circuit				

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in this document has been subjected to the series of proving tests in accordance with: IEC 60076-5 (February 2006) Subcl. 4.2

The results are shown in the record of proving tests and the oscillograms attached hereto. The ratings assigned by the Manufacturer are listed on the ratings page.
The document applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

September 7, 2019

Date	Levati Mario <small>B9016944 2961 AUT</small> Test Engineer in charge	The Manager - Arcidiaco Lorenzo <small>B9016944 821814 AFP</small> Approved By
------	---	--

Partial reproduction of this document is permitted only with the written permissions from CESI Group.
The authenticity of this document is guaranteed by the integrity of hologram.



CESI

Trust the Power of Experience